

ADDENDUM # 1
Naperville Public Library
Access Control RFP
Questions thru July 18, 2019

1. How many card readers are in the three buildings?
 - Currently, there is a total of 59 card readers.
 - i. 31 readers at the Nichols Library
 - ii. 15 readers at the 95th St. Library
 - iii. 13 readers at the Naper Blvd. Library.
2. Are all the buildings networked together?
 - Yes, with the server located at 95th St. Library.
3. Is all the administrative work done at the 95th St. Library?
 - Yes.
4. Will the access control and cameras be integrated?
 - No.
5. Do you have duress buttons? If so, are they integrated in this system?
 - No.
6. Who is to supply the badges? Will they work with the new software?
 - We supply our badges.
 - Yes, they are to work with the new software. They are HID badges and HID readers, which are not being changed and are compatible with the new software.