

**ADDENDUM # 1**  
**Naperville Public Library**  
**Flooring Removal and Installation RFP**  
**-95<sup>th</sup> Street Library**  
**Questions thru November 5, 2018**

1. The drywall overhangs the cove base in the larger meeting rooms. The area is too small for 6" cove base that is in the specifications. What size should we use?
  - For the Meeting Rooms A and B, please use Johnsonite Flooring 4"H, Color: 48 Grey. All other spaces please use the cove base in the original specification.
2. Do we install transition strips?
  - Yes, please install transition strips wherever appropriate.
3. Who will assist in moving furniture?
  - Library staff will assist in moving furniture in the office spaces.
4. Does this have to be prevailing wage?
  - Yes.