

ADDENDUM # 1
Naperville Public Library
Indoor Generator - RFP
Questions thru August 16, 2018

1. Is the generator unit located below grade?
 - Yes, the unit is located on the lower level of the building.
2. Is there a set of drawings?
 - There is not an original set.
 - If needed, we could provide a more recent set.
3. Are we to re-use the existing exhaust and silencer?
 - The intent is to re-utilize this equipment.
 - If determined later, a change order can be issued for replacement of this equipment.
4. How are we to remove the old unit and bring in the new unit?
 - There are various ways in and out of the space.
 - Library staff will work final details with the awarded bidding company.
5. When removing the old ATS and installing the new ATS, a power outage will exist. The work window noted in this RFP is M-F, 7A-5P. Will the outage be allowed during the published work window or will it occur outside of that window of time? If outside the published window, then when?
 - When working on the Transfer Switch: Vendor will provide a temporary means of carrying the generator's load while the transfer switch is disconnected and being replaced.
 - When the generator is being worked on: Vendor will provide a temporary portable back-up generator to be used in the event of a power outage while the old generator is disconnected, and the new generator is being installed.
 - The outages will be allowed during the posted timeframes.